

CENTRALE TERMICA FOSSOLO Soc. Coop.va

ESERCIZIO RISCALDAMENTO 2020 - 2021

Sottocentrale N°	Ubicazione Sottocentrale	Consumi kWh	Volume m ³ Riscaldati	Rapporto kWh/m ³	
1	Via MISA 3 - 5 - 7	832.570	29.356,99	28,360	
2	Via MISA 9÷13	547.650	21.207,34	25,824	CONSUMI
3	Via MISA 21-23	543.310	18648,12	29,135	Valutazioni esclusa scuola
4	Via MISA 25÷35	788.600	30.412,67	25,930	
5	Via MISA 41÷51	687.650	25.983,80	26,465	Valore
6/7	Via Roselle 2÷12	719.330	29.506,84	24,378	MINIMO
8	Via Roselle 14÷18	473.100	21.176,32	22,341	21,6256
9	Via SPINA 15÷25	709.150	26.011,37	27,263	kWh/m ³
10	Via SPINA 27-29	586.080	19.138,03	30,624	
11	Via SPINA 31÷41	736.290	28.356,74	25,965	Valore
12	Viale Felsina 27-29	617.940	18.648,12	33,137	Medio
13	Via Vetulonia 1÷13	1.060.560	34.412,74	30,819	Globale
Scuola materna	Comune Bologna - Follerau	71.880	1.360,69	52,826	30,286
14	Via Allende 1-3-1 ² -1 ³	744.410	24.316,25	30,614	kWh/m ³
15	Via Allende 2÷6	1.052.720	38.146,63	27,597	
16	Via Allende FN3	1.575.000	52.418,07	30,047	Valore
17	Via Allende-Neruda FN3	1.409.760	46.913,10	30,050	MASSIMO
18	Via Neruda 2-4	531.710	24.587,11	21,626	33,1369
19	Via Neruda 5÷11	821.300	30.511,69	26,918	kWh/m ³
20	Via Neruda 13÷19	734.000	28.761,71	25,520	

15.243.010 549.874,33

kWh

m³